



School of Engineering

GPO Box 2476 Melbourne VIC 3001 Australia

CERTIFICATE OF TEST

11 December 2020

Test	Combustibility of materials in accordance with AS 1530.1:1994		
Test reports #	IFFE201231.1;	IFFE201232.1; and	IFFE201233.1.
Sponsor	Adelaide Brighton Cement Ltd	Address	PO Box 77, Port Adelaide SA 5015
Product names	Euromix Render;	Euromix Cream; and	Euromix Skim Coat.
Test results	All three products are deemed not combustible according to test results and combustibility criteria (AS 1530.1:1994)		

This certificate is a summary of three reports above and should only be used in conjunction with these reports.

This certificate and tests were not produced/conducted by a NATA-accredited testing facility.

These test results relate only to the behaviour of the test specimens of the material under particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

Every reasonable care is taken to ensure that the reports are accurate. The University does not accept responsibility for any reliance on the reports or consequences from the further use of these reports by third parties.

The sponsor agrees to indemnify, defend and hold the University harmless from and against all losses, expenses, damages and costs, including reasonable legal fees arising out of or relating to any third-party reliance on the contents of the report.

Certificate prepared by Dr Kate Nguyen

Email: kate.nguyen@rmit.edu.au

Phone: 03 9925 8164

